



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ  
Dilovası OSB Mahallesi Fırat Caddesi No: 18  
Dilovası, Kocaeli / TÜRKİYE  
www.efectis.com

## DECLARATION OF TEST RESULTS

No: ERA-2100-0017

The related reaction to fire tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory between 27<sup>th</sup> July 2021. Classification of reaction to fire has been carried out in accordance the standard:

**EN 13501-1:2018**

“Flexiva Sky Insulated / Lux Alesbo”

Fire behaviour		Smoke production		Flaming droplets
C	-	s	1	, d 0

**Flammability Classification\***

**Hardly inflammable**

\*Turkey's regulation on fire protection 2009, Appendix-2/Ç the table of flammability classification of construction materials in accordance with EN 13501-1

Placed on the market by: IŞIL MÜH. MAK. VE İNŞ. SAN. TİC. A.Ş.  
Kurtköy Mah. Hızır Reis Cad. No:9/1 Pendik, İstanbul / TURKEY

Manufactured by: IŞIL MÜH. MAK. VE İNŞ. SAN. TİC. A.Ş.  
Kurtköy Mah. Hızır Reis Cad. No:9/1 Pendik, İstanbul / TURKEY

Ali BAYRAKTAR  
Laboratory Manager  
02.08.2021



This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: ERA-21-114.