


Exova Warringtonfire
Holmesfield Road
Warrington
WA1 2DS
United Kingdom

T : +44 (0) 1925 655116
F : +44 (0) 1925 655419
E : warrington@exova.com
W: www.exova.com



BS 476: Part 7: 1997



Method For Classification Of The Surface Spread Of Flame Of Products

A Report To: İŞİL MÜHENDİSLİK MAKİNA VE İNŞAAT SAN. TİC. A.Ş.

Document Reference: 383012

Date: 9th May 2017

Issue No.: 1

Page 1

Testing
Advising
Assuring



Executive Summary

Objective To determine the surface spread of flame classification of the following product when tested in accordance with BS 476: Part 7: 1997.

Generic Description	Product reference	Thickness	Weight per unit area or density
Uninsulated flexible air duct	"FLEXIVA SKY/ ESBO LUX ALESBO/ AIRBOX"	50 microns	0.17kg/m ² *
Individual components used to manufacture composite:			
Aluminium polyester lamination	Unwilling to provide	21 microns	19.04g/m ²
Adhesive	Unwilling to provide	3 microns	Not stated
*Determined by Exova Warringtonfire			
Please see pages 5 & 6 of this test report for the full description of the product tested			


Test Sponsor İŞİL MÜHENDİSLİK MAKİNA VE İNŞAAT SAN. TİC. A.Ş., Yayalar Mah. Akın Sok. No: 18/1, 34909 Pendik - Istanbul / Turkey

Test Results: **Class D1**


An uncertainty of measurement estimation has been conducted in relation to the distance travelled by the flame front and the findings are as detailed on page 9.

Date of Test 3rd May 2017

Signatories



Responsible Officer
C. Meachin *
Technical Officer



Authorised
B. Dean *
Technical Leader

* For and on behalf of **Exova Warringtonfire**.

Report Issued: 9th May 2017

This version of the report has been produced from a pdf format electronic file that has been provided by **Exova Warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Exova Warringtonfire**.

Document No.: 383012

Page No.: 2 of 11

Author: C. Meachin

Issue Date: 9th May 2017

Client: İŞİL MÜHENDİSLİK MAKİNA VE İNŞAAT SAN. TİC. A.Ş.

Issue No.: 1



CONTENTS	PAGE NO.
EXECUTIVE SUMMARY	2
SIGNATORIES.....	2
TEST DETAILS.....	4
DESCRIPTION OF TEST SPECIMENS.....	5
TEST RESULTS	7
APPENDIX 1 – TEST RESULTS.....	8
APPENDIX 2 – CLASSIFICATION CRITERIA	10
REVISION HISTORY	11

Test Details

Purpose of test	To determine the performance of a product when it is subjected to the conditions of the test specified in BS 476: Part 7: 1997, "Fire tests on building materials and structures, method for classification of the surface spread of flame of products". This test was therefore performed in accordance with the procedure specified in BS 476: Part 7: 1997 and this report should be read in conjunction with that British Standard.
Scope of test	BS 476: Part 7: 1997 specifies a method of test for measuring the lateral spread of flame along the surface of a specimen of a product orientated in the vertical position, and a classification system based on the rate and extent of flame spread. It provides data suitable for comparing the performances of essentially flat materials, composites, or assemblies, which are used primarily as the exposed surfaces of walls or ceilings.
Fire test study group/EGOLF	Certain aspects of some fire test specifications are open to different interpretations. The Fire Test Study Group and EGOLF have identified a number of such areas and have agreed Resolutions which define common agreement of interpretations between fire test laboratories which are members of the Groups. Where such Resolutions are applicable to this test they have been followed.
Instruction to test	The test was conducted on the 3 rd May 2017 at the request of İŞİL MÜHENDİSLİK MAKİNA VE İNŞAAT SAN. TİC. A.Ş., the sponsor of the test.
Provision of test specimens	The specimens were supplied by the sponsor of the test. Exova Warringtonfire was not involved in any selection or sampling procedure.
Conditioning of specimens	The specimens were received on the 26 th April 2017 and were conditioned to constant mass at a temperature of $23 \pm 2^{\circ}\text{C}$ and a relative humidity of $50 \pm 5\%$ prior to testing.
Form in which the specimens were tested	Assembly - Fabrication of materials and/or composites that can contain air gaps. Each specimen was placed over 25mm thick by 20mm wide calcium silicate based spacers positioned around its perimeter and mounted onto a backing board so that a 25mm enclosed air gap was provided between the unexposed face of the specimen and the backing board.
Exposed face	One of two identical faces of the specimens was exposed to the heating conditions of the test.

Document No.:	383012	Page No.:	4 of 11
Author:	C. Meachin	Issue Date:	9 th May 2017
Client:	İŞİL MÜHENDİSLİK MAKİNA VE İNŞAAT SAN. TİC. A.Ş.	Issue No.:	1



Description of Test Specimens

The description of the specimens given below has been prepared from information provided by the sponsor of the test. All values quoted are nominal, unless tolerances are given.

General description		Uninsulated flexible air duct
Product reference		"FLEXIVA SKY/ ESBO LUX ALESBO/ AIRBOX"
Name of manufacturer		IŞIL MÜHENDİSLİK MAK. Ve İNŞ. SAN.TİC. A.Ş.
Thickness		50microns (stated by sponsor) 0.05mm (determined by Exova Warringtonfire)
Weight per unit area		0.17kg/m ² (determined by Exova Warringtonfire)
Product configuration		<ul style="list-style-type: none"> Aluminium polyester lamination Adhesive Aluminium polyester lamination
Aluminium polyester lamination	Generic type	Aluminium polyester lamination
	Product reference	See Note 1 Below
	Composition details	<ul style="list-style-type: none"> Aluminium (7 micron) Glue Polyester (12 micron)
	Name of manufacturer	See Note 1 Below
	Thickness	21 microns
	Density	2.72g/cm ³
	Weight per unit area	19.04g/m ²
	Colour reference	"Silver"
	Flame retardant details	See Note 2 Below
Adhesive	Generic type	See Note 1 Below
	Product reference	See Note 1 Below
	Name of manufacturer	See Note 1 Below
	Colour reference	"Transparent"
	Application thickness	3 microns
	Application method	Automatic
	Flame retardant details	See Note 2 Below
	Curing process	Automatic

Continued on next page

Specimen construction details	'FLEXIVA SKY/ ESBO LUX ALESBO/ AIRBOX' ducting in practice would encapsulate a high tensile steel wire helix to form the wall of the air ducting. It is not practicable to include the wire helix within the specimens and for this reason; the laminate only was tested with a (12.5) 25mm airspace at the back of the product. It is considered that the inclusion of the wire helix would not have any detrimental effect on the flame-spread characteristics of the actual product. Since the specimens consist of a modified version of the actual product, a prefix 'D' is added to the classification (see Appendix 1)
Brief description of manufacturing process	Automatically production via flexible duct production line

Note 1: The sponsor was unwilling to provide this information.

Note 2: The sponsor of the test has confirmed that no flame retardant additives were utilised in the production of the component.

The description of the specimens as given above is not as detailed as would usually be the case for descriptions included in **Exova Warringtonfire** test reports and the description may not fully comply with the requirements of the test standard. In all other respects however the tests were conducted fully in accordance with the requirements of the test standard and the test results are valid.

Document No.: 383012

Page No.: 6 of 11

Author: C. Meachin

Issue Date: 9th May 2017

Client: İŞİL MÜHENDİSLİK MAKİNA
VE İNŞAAT SAN. TİC. A.Ş.

Issue No.: 1



0249

Test Results

Results and observations	The test results for the individual specimens, together with observations made during the test and comments on any difficulties encountered during the test are given in Appendix 1.
Classification	<p>In accordance with the class definitions given in BS 476: Part 7: 1997; the specimens tested are classified as Class D1.</p> <p>An uncertainty of measurement estimation has been conducted in relation to the distance travelled by the flame front and the findings are as detailed on page 9.</p>
Criteria for classification	If the prefix 'D' or suffix 'R' or 'Y' is included in the classification, this indicates that the results should be treated with caution. An explanation of the reason for the prefix and suffixes is given in Appendix 2, together with the classification limits specified in the Standard.
Applicability of test result	<p>The test results relate only to the behaviour of the test specimens of the product under the particular conditions of test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.</p> <p>The test results relate only to the specimens of the product in the form in which they were tested. Small differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product which is supplied or used is fully represented by the specimens which were tested.</p>
Validity	<p>The specification and interpretation of fire test methods are the subject of ongoing development and refinement. Changes in associated legislation may also occur. For these reasons it is recommended that the relevance of test reports over five years old should be considered by the user. The laboratory that issued the report will be able to offer, on behalf of the legal owner, a review of the procedures adopted for a particular test to ensure that they are consistent with current practices, and if required may endorse the test report.</p> <p>This report may only be reproduced in full. Extracts or abridgements shall not be published without permission of Exova Warringtonfire.</p>

Appendix 1 – Test Results

SPECIMEN No.	1	2	3	4	5	6
Maximum distance travelled at 1.5 minutes (mm)	70	70	70	70	70	70
Distance (mm)	Time to travel to indicated distance (minutes : seconds)					
75						
165						
190						
215						
240						
265						
290						
375						
455						
500						
525						
600						
675						
710						
750						
785						
825						
Time to reach maximum distance travelled	1:00	1:00	1:02	1:00	1:07	1:00
Maximum distance travelled in 10 minutes (mm)	70	70	70	70	70	70

Note: Six specimens are usually tested. If the test on any specimen is deemed to be invalid, as defined in the Standard, it is permissible for up to a maximum of nine specimens to be tested in order to obtain the six valid test results.

Observations made during test and comments on any difficulties encountered during the test:

None.

Document No.: 383012

Author: C. Meachin

Client: İŞİL MÜHENDİSLİK MAKİNA VE İNŞAAT SAN. TİC. A.Ş.

Page No.: 8 of 11

Issue Date: 9th May 2017

Issue No.: 1



0249

**Uncertainty of
 measurement**

Specimen No.	1	2	3	4	5	6
Maximum distance travelled at 1.5 minutes (mm)	±4	±4	±4	±4	±4	±4
Maximum distance travelled in 10 minutes (mm)	±4	±4	±4	±4	±4	±4

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor $k=2$, providing a coverage probability of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

Appendix 2 – Classification Criteria

Classification of spread of flame

Classification	Spread of Flame at 1.5 min		Final Spread of Flame	
	Limit (mm)	Limit for one specimen (mm)	Limit (mm)	Limit for one specimen (mm)
Class 1	165	165 + 25	165	165 + 25
Class 2	215	215 + 25	455	455 + 45
Class 3	265	265 + 25	710	710 + 75
Class 4	Exceeding the limits for class 3			

Explanation of prefix and suffixes which may be added to the classification

1. A suffix R is added to the classification if more than six specimens are required in order to obtain six valid test results (e.g. class 2R).
2. A prefix D is added to the classification of any product which does not comply with the surface characteristics specified in the Standard and has therefore been tested in a modified form (e.g. class D3).
3. A suffix Y is added to the classification if any softening and/or other behaviour that may affect the flame spread occurs (e.g. class 3Y).

For example, a classification of D3RY could be achieved indicating (a) a modified surface has been used; (b) a class 3 result has been obtained; (c) additional specimens have been used to obtain 6 valid results and; (d) softening and/or other behaviour has occurred which is considered to have affected the test result.

Revision History

Issue No :	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	

Issue No :	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	